

7338



TECHNICAL STANDARDS and SAFETY AUTHORITY
 14th Floor, Centre Tower
 3300 Bloor Street West
 Toronto, Ontario M8X 2X4
 Toll free 1-877-682-8772
 www.tssa.org

FS Inspection Report

APR 08 2016

Service Request #	1829460
Inspection Report #	6096395

Inspection Address: MANITO LANDING TEMAGAMI ACCESS RD TEMAGAMI;ON CA P0H 2H0	Reference Number(s):	Inspection Completion Date: MAR 11, 2016
	Facility Type:	Equipment Type:
Customer Name and Address: MUNICIPALITY OF TEMAGAMI 7 LAKESHORE DR PO BOX 220 TEMAGAMI;ON CA P0H 2H0	Task Type: FS-Unscheduled Inspect	
	The facility/equipment is inspected in accordance with Ontario's Technical Standards & Safety Act and the appropriate regulations and codes. When an Inspector's order is issued, time limits for compliance reflect the severity of the violation and serve to avoid disruption of service.	

Orders Issued To: Municipality of Temagami and Monty Cummings (chief building official)

Line	Reference and Order(s)	Compliance Date
75650 1-1	CAN/CSA-B149.2-10 Propane Storage and Handling Code. 5.3.2 When containers are installed or stored in locations that do not afford protection from damage from motor vehicles on any street, highway, avenue, alley, or parking lot, they shall be protected by posts or guardrails in compliance with Clause 7.19.4 unless otherwise approved by the authority having jurisdiction. Pursuant to the B149.2 Code You are hereby ordered to cease and desist from storing and or allowing the storage of propane at the above mentioned location in a manner that does not satisfy the requirements of the Code. Inspector Wells determined that unsafe propane storage is taking place at the above mentioned location. The Municipality of Temagami has a land use permit in place for the location and is allowing persons to store propane which is not secured or being stored properly. A proper propane storage shall be erected or all propane shall be removed from the site.	JUN 30, 2016
75650 1-2	CAN/CSA-B149.2-10 Propane Storage and Handling Code. 6.5.2.1 Except as permitted in Clauses 6.5.2.5, 6.5.3.2, 6.5.4.2, and 6.5.5.2, cylinders shall be fenced in accordance with Clause 6.5.2.2 or 6.5.2.3 or shall be enclosed in a storage cabinet in accordance with Clause 6.5.2.4. Pursuant to the B149.2 Code You are hereby ordered to cease and desist from storing and or allowing the storage of propane in a manner that does not satisfy the requirements of the Code. Inspector Wells determined that the Municipality of Temagami is allowing persons to store propane at the above mentioned location in a manner that does not satisfy the requirements of the Code. A proper propane storage shall be installed or all propane shall be removed from the location.	JUN 30, 2016
75650 1-3	CAN/CSA-B149.2-10 Propane Storage and Handling Code. 6.5.2.4 (amended) If cylinders stored outdoors are enclosed in a storage cabinet, the storage cabinet shall fulfill the following requirements: (a) It shall be at least 6 ft (2 m) high, measured from grade level, unless supplied with a top cover. (b) The wall or top cover material shall be either metal wire of not less than No. 9 SWG (3.7 mm), having openings not greater than 2 x 2 in (50 x 50 mm), or sheet metal. (c) It shall be ventilated to the outside air on both the top and the bottom of the cabinet, at minimum. (d) It shall be maintained in an upright position. Pursuant to the B149.2 Code You are hereby ordered to ensure all propane storage at the above mentioned location is performed in a manner that satisfies the requirements of the Code. Inspector Wells determined that the propane storage at the above mentioned location does not satisfy the requirements of the Code. The facility does not currently have proper propane storage.	JUN 30, 2016

- File
- Incoming
- Other
- Mayor
- Council 01 A
- CAO
- Building
- Finance S C
- Ec Dev S C
- Parks & Rec S C
- Planning S C
- Public Wks S C
- PPP
- Social Services

Customer Signature & Position / Date:		Inspector Name: Wells, Adam	Inspector Contact Number: 705-758-1862
Report Received By: emailed to Mr Cummings building@temagami.ca	Customer Contact Number: 705-569-3421	Inspector Email: AWells@tssa.org	Inspector Fax: 705-758-1865

As a not-for-profit regulatory authority, TSSA operates on a cost recovery basis. An Invoice will be issued for the Total Charges Incurred.
 (Note: This is not an invoice)

Putting Public Safety First



**TECHNICAL STANDARDS
and SAFETY AUTHORITY**

14th Floor, Centre Tower
3300 Bloor Street West
Toronto, Ontario M8X 2X4
Toll free 1-877-682-8772
www.tssa.org

FS Inspection Report

Service Request #	1829460
Inspection Report #	6096395

Inspection Address: MANITO LANDING TEMAGAMI ACCESS RD TEMAGAMI;ON CA P0H 2H0	Reference Number(s):	Inspection Completion Date: MAR 11, 2016
	Facility Type:	Equipment Type:
Customer Name and Address: MUNICIPALITY OF TEMAGAMI 7 LAKESHORE DR PO BOX 220 TEMAGAMI;ON CA P0H 2H0	Task Type: FS-Unscheduled Inspect	
	The facility/equipment is inspected in accordance with Ontario's Technical Standards & Safety Act and the appropriate regulations and codes. When an Inspector's order is issued, time limits for compliance reflect the severity of the violation and serve to avoid disruption of service.	

Task Notes
Inspector Wells performed a site inspection at the above mentioned location on March 11-2016 for the purpose of determining the location and storage of propane. Inspector Wells determined that the Municipality of Temagami is the holder of a Land Use Permit and as such is the responsible party for the storage of propane at the site. Proper propane storage shall be installed or all propane shall be removed from the site.

Standard Notes
Every person who,(a) contravenes or fails to comply with any provision of this Act, the regulations or a Minister's order;(b) knowingly makes a false statement or furnishes false information under this Act, the regulations or a Minister's order;(c) contravenes or fails to comply with a term or condition of an authorization;(d) contravenes or fails to comply with an order or requirement of an inspector or obstructs an inspector,is guilty of an offence and on conviction is liable to a fine of not more than \$50,000 or to imprisonment for a term of not more than one year, or to both, or, if the person is a body corporate, to a fine of not more than \$1,000,000.(Technical Standards and Safety Act, 2000, Section 37 (1))

Customer Signature & Position / Date:		Inspector Name: Wells, Adam	Inspector Contact Number: 705-758-1862
Report Received By: emailed to Mr Cummings building@temagami.ca	Customer Contact Number: 705-569-3421	Inspector Email: AWells@tssa.org	Inspector Fax: 705-758-1865

As a not-for-profit regulatory authority, TSSA operates on a cost recovery basis. An Invoice will be issued for the Total Charges Incurred.
(Note: This is not an invoice)